

TEST REPORT

160 Frobisher Drive, Unit 5, Waterloo, Ontario, Canada N2V 2B1
Tel: (519)746-3140 Email: services@lumentra.com



LUMENTRA, INC.
160 FROBISHER DRIVE, UNIT 5
WATERLOO, ONTARIO

TEST REPORT NO. XXX6S
SUPPLEMENTARY MEASUREMENTS

COMPANY XYZ FLOODLIGHT LUMINAIRE CAT. NO. XXX6
WITH SPECULAR REFLECTOR AND CLEAR FLAT GLASS LENS
ARRAY OF WHITE LEDS. LUMEN OUTPUT = 6353 LMS.
COMPANY ABC 120V LED DRIVER MODEL ABC1

CHROMATICITY MEASUREMENTS	
CIE 1931-x:	0.362
CIE 1931-y:	0.365
CORRELATED COLOUR TEMPERATURE:	4469 K
COLOUR RENDERING INDEX:	78.0

LUMENTRA IS ACCREDITED TO ISO/IEC 17025:2005.

PREPARED FOR: XYZ COMPANY
SOMEWHERE, ONTARIO

DATE: JANUARY 7, 2014

PREPARED BY:

A handwritten signature in black ink that reads "Charles Sisson".

CHARLES SISSON